

GEOTECH

TESTING PTY LTD[®]

ABN 71 076 676 321

Client: P F FORMATION
1774 WISEMANS FERRY ROAD
MAROOTA NSW 2756

Job No 7018/1
Date: 12/10/2019
Tested By: SS
Checked By: EVN

Project: MATERIAL ASSESSMENT
QUARRY SAMPLE TESTING, EMU PLAINS DEPOT

TEST RESULTS

Page 1 of 1

TEST PROCEDURE AS1141.11.1 (DRY SIEVING), 12	
Material Description	Bricklaying SAND - White
Sieve Analysis	
Laboratory Number	7018/1-1576
<u>Sieve Size</u>	Percentage Passing
9.5mm	100
4.75mm	100
2.36mm	97
1.18mm	81
600 microns	37
300 microns	5
150 microns	1
75 microns	10.8
Date Sampled	30/9/2019
Sampling Procedure	Sampled by Client. Results apply to sample as received.
Sampling Location	Ex Maroota Quarry

Form No: R024 Version 05 06/13 - issued by ER



Nata Accreditation Number 2734

Corporate Site Number 2727

Accredited for compliance with ISO/IEC 17025 - Testing.

E Van Niekerk

12/10/2019

Approved Signatory

34 Borec Road, Penrith NSW 2750
Telephone: (02) 4722 2744

Unit 4, 18-20 Whyalla Place, Prestons NSW 2170
Telephone: (02) 9607 6111

email: info@geotech.com.au www.geotech.com.au