

# GEOTECH

TESTING PTY LTD<sup>®</sup>

ABN 71 076 676 321

Client: P F FORMATION  
1774 WISEMANS FERRY ROAD  
MAROOTA NSW 2756

Job No 7018/1  
Date: 12-Oct-19  
Tested By: 12/10/2019  
Checked By: EVN

Project: MATERIAL ASSESSMENT  
QUARRY SAMPLE TESTING, EMU PLAINS DEPOT

## TEST RESULTS

Page 1 of 1

TEST PROCEDURE AS1141.11.1 (DRY SIEVING), 12	
Material Description	Bricklaying SAND - Yellow
Sieve Analysis	
Laboratory Number	7018/1-1575
<u>Sieve Size</u>	<u>Percentage Passing</u>
9.5mm	100
4.75mm	98
2.36mm	92
1.18mm	77
600 microns	51
300 microns	12
150 microns	3
75 microns	10.9
Date Sampled	25/9/2019
Sampling Procedure	Sampled by Client. Results apply to sample as received
Sampling Location	Ex Maroota Quarry

Form No: R024 Version 05 06/13 - issued by ER



Nata Accreditation Number 2734

Corporate Site Number 2727

Accredited for compliance with ISO/IEC 17025 - Testing.

E Van Niekerk 12/10/2019

Approved Signatory

34 Borec Road, Penrith NSW 2750  
Telephone: (02) 4722 2744

Unit 4, 18-20 Whyalla Place, Prestons NSW 2170  
Telephone: (02) 9607 6111

email: info@geotech.com.au www.geotech.com.au