



Client: P F FORMATION  
1774 WISEMANS FERRY ROAD  
MARROOTA NSW 2756

Job No 7018/1  
Date Tested: 24/06/2024  
Tested By: SV  
Checked By: AK

Project: MATERIAL ASSESSMENT  
QUARRY SAMPLE TESTING, EMU PLAINS DEPOT

## TEST RESULTS

TEST PROCEDURE AS1141.11.1 (DRY SIEVING), 12 & 33		
Material Description	Fine SAND	
Sieve Analysis		
Laboratory Number	7018/1-2071	
<u>Sieve Size</u>	Percentage Passing	Pre-treatment Nil - Standard Oven Drying
9.5mm	100	<b>Moisture Content % AS1289 2.1.1</b>
4.75mm	100	
2.36mm	100	<b>1.0</b>
1.18mm	98	<b>% Clay &amp; Fine Silt (Settling Method)</b>
600 microns	90	
300 microns	30	
150 microns	2	
75 microns	1.2	<b>4.0</b>
Date Sampled	11/06/2024	
Sampling Procedure	Sampled by Client. Results apply to sample as received	
Sampling Location	Ex Maroota Quarry	

Form No: R 025 Version 05/06/13 - issued by ER



Nata Accreditation Number 2734  
Corporate Site Number 2727

Accredited for compliance with ISO/IEC 17025.

A Kench

26/06/2024