

Material Test Report

Report Number: 9810-1
Issue Number: 1
Date Issued: 17/02/2025
Client: P F FORMATION
 1774 WISEMANS FERRY ROAD, MARROOTA NSW 2756
Project Number: 9810
Project Name:
Project Location: 1 Patricia Fay Drive Maroota, NSW 2765
Work Request: 311
Sample Number: S-311F
Date Sampled: 29/01/2025
Dates Tested: 13/02/2025 - 17/02/2025
Sampling Method: Sampled by Client
The results apply to the sample as received
Preparation Method: AS 1289.1.1 - Sampling and Preparation of Soils
Sample Location: Coarse Sand
Material: Coarse Sand



Geotech Testing Pty Ltd
 Penrith Laboratory
 34 Borec Road Penrith NSW 2750
 Phone: (02) 4722 2744
 Email: matthew@geotech.com.au

Accredited for compliance with ISO/IEC 17025 - Testing



Approved Signatory: Mathew Morley
 Laboratory Manager
 NATA Accredited Laboratory Number: 2734

Particle Size Distribution (AS1141.11.1)			
Sample Washing	Sample was Washed		
Sieve	Passed %	Passing Limits	
75 mm	100		
63 mm	100		
53 mm	100		
37.5 mm	100		
26.5 mm	100		
19 mm	100		
13.2 mm	100		
9.5 mm	100		
6.7 mm	100		
4.75 mm	100		
2.36 mm	96		
1.18 mm	84		
0.6 mm	64		
0.425 mm	46		
0.3 mm	21		
0.15 mm	3		
0.075 mm	1		

Clay and Fine Silt (AS 1141.33)			
	Min	Max	
Volume of Clay and Silt (%)	5		

